

## Department of Health

ANDREW M. CUOMO Governor HOWARD A. ZUCKER, M.D., J.D. Commissioner

LISA J. PINO, M.A., J.D. Executive Deputy Commissioner

May 6, 2021

Charles Walz, P.E. 2 Johnson Ave. Mohawk, NY 13407

Re:

Camparounds

Pine Lake Campground Expansion

Caroga (T) Fulton County

Dear Mr. Walz:

Plans for the expansion of 24 RV sites in the Pine Lake Resort Village section of the park have been reviewed by this Office. The following information must be provided before this Office can complete its review and acceptance of the project:

- The plan does not include a 100 and 200 foot radius delineation from the well to show that all planned and existing septic systems are at least 100 feet from the well. Please provide this information on the revised plans.
- 2) The detail of the septic systems and associated leach field(s) for sites 115, 117, 119, and 121 located along Woodpecker Way has not been shown on the plans. Please provide this information on the resubmittal.
- 3) There is a leach field designated on the plans with dotted lines, however it is not clear from the plans how and what sites this leach field serves. Please provide this information and include the location of all the associated septic system components (i.e. septic tank(s) and distribution box) and indicate how those components are connected to each site.
- 4) The septic waste lines from some sites to the septic tank have extended runs, so cleanouts should be added at intervals that would make clearing any plugged solids from these lines practical. Please add this notation on the revised plans.
- 5) A typical water, septic and electrical riser detail from the sites has not been provided on the plan. Please be advised this detail must include the type of back flow prevention devices that will be provided at each potable water connection. Please include this detail on the plan resubmittal.
- 6) A typical site detail showing the dimensions of the new sites and the construction material for the RV pads has not been provided on the plans. Please provide this with the resubmission.
- 7) The make and model of the leach field infiltrators has not been provided on the plan. Please make this notation on the plan and provide a manufacturer's cut sheet with the resubmission.

Once the revised plans are provided, this Office can complete the review and acceptance of this project. If you have any questions, please contact this Office at 315-866-6879.

Sincerely

Donald Van Patter District Director

CC:

Anthony Fancher, CEO, Caroga (T)

Jeff Houck, Owner

ecc:

Todd Mull/Cindy White, HDO